

ADDENDUM #3

**Warm Springs WMA Cold
Storage Building
FWP #7135359**

Warm Springs, Montana
January 27, 2021

Bidders for the above listed project are hereby notified that the following changes have been made to the bid documents:

1. Light Fixture – Prior Approvals:

The following light fixtures have been reviewed as equals, subject to final approval, to specified light fixtures:


Fixture “B” Stonco

2. Replace TECHNICAL SPECIFICATION 07 4113 Metal Roof Panels, Section 2.01A.3 as follows:

3. Span: The metal roof panel must be able to span 3’-0”

3. Replace TECHNICAL SPECIFICATION 07 4113 Metal Roof Panels, Section 2.01B.6 as follows:

6. Width: Maximum panel coverage of 3’-0”



Jeffrey L. Larson, P.E.

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE DESIGNATED PLACE IN THE BID FORM AND ON THE FACE OF THE ENVELOPE.