



MONTANA FISH, WILDLIFE & PARKS

ADDENDUM NO. 1

TO: ALL BIDDERS OF RECORD

PROJECT: Beckman WMA Waterline Extension

FWP PROJECT #: 7155312

DATE: 3/3/2021

FROM: Joey Renenger, Montana FWP Project Manager

Acknowledge receipt of this addendum by inserting its number and date in the Proposal Form and on the Bid Envelope. Failure to do so may subject bidder to disqualification.

This Addendum forms a part of the Contract Documents. Clarification and/or modifications area as follows:

1. *Modify PROPOSAL – BASE BID Item #8 as follows:*

Replace *Description* with “Install 1000 Gallon Minimum Stock Tank with Cattle Guards”

2. *Modify Technical Specification Section 01010 – Summary or Work Section 1.3.B.8 Install 1500 Gallon Stock Tank with Cattle Guards as follows:*

Replace wording “1500 gallon stock tank” with “1000-gallon minimum stock tank” in all three locations that it appears in this section.

3. *Modify Section 02802 Water Troughs Section 2.1.A as follows:*

Tank shall be Component Structure Systems model R-10 or equal.

4. *Modify Plan Set Sheet 2 of 6 – Table – Item 8 as follows:*

Replace *Description* with “Install 1000 Gallon Minimum Stock Tank with Cattle Guards”

5. **Modify Plan Set Sheet 5 of 6 – Tank Installation Detail** as follows:

Replace “12’ Dia. Stock Tank , MIN CAPACITY 1500 GALLONS” with “10’ Dia. Stock Tank , MIN CAPACITY 1000 GALLONS”.

The intent of this addendum is to amend the project to include a 10’ diameter stock tank with a minimum capacity of 1000 gallons rather than the 1500-gallon stock with a 12’ diameter that was originally called out. The gravel base for the stock tank will still be 24’ in diameter and the tank will still need to have gravel retainers and cattle guards installed. Any deviation from a 10’ diameter stock tank with a minimum capacity of 1000 gallons will need to be approved by the project Engineer.

END OF ADDENDUM NO. 1