



MONTANA FISH, WILDLIFE & PARKS

ADDENDUM NO. 1

TO: ALL BIDDERS OF RECORD

PROJECT: Lewis and Clark Caverns State Park Re-roof

FWP PROJECT #: 7196113

DATE: September 2, 2021

FROM: Kevin Harrington, Project Manager

Kevin Harrington
9.2.21

Acknowledge receipt of this addendum by inserting its number and date in the Proposal Form and on the Bid Envelope. Failure to do so may subject bidder to disqualification.

This Addendum forms a part of the Contract Documents. Clarification and/or modifications are as follows:

1. This addendum is to provide clarification on **Technical Specification 075416 Ethylene Interpolymer (KEE) Roofing:**
 - EPDM 60 mil WeatherBond membrane or approved equal shall be used to replace the existing roll roofing as shown on the plans and match the existing EPDM membrane installed in 2020 with concessions improvement project.
 - Installation shall follow all manufacturers recommendations for EPDM roofing.
 - Disregard all references in specification 075416 to (KEE) roofing as a possible substitute for this project.