



MONTANA FISH, WILDLIFE & PARKS

ADDENDUM NO. 2

TO: ALL BIDDERS OF RECORD

PROJECT: Lone Pine State Park Water System Improvements

FWP PROJECT #: 7176312

DATE: January 26, 2022

FROM: Randi Rognlie, Montana FWP Project Manager

Acknowledge receipt of this addendum by inserting its number and date in the Proposal Form and on the Bid Envelope. Failure to do so may subject bidder to disqualification.

This Addendum forms a part of the Contract Documents. Clarification and/or modifications area as follows:

1. A note on plan sheet 11 of 20 states the following:

Note: The well pump that is existing is a Franklin Tri Seal 10GS30 based upon best records available. This shall be verified on site during the construction process. The pump replacement shall be bid as an optional item and the contractor shall match the existing pump with the replacement.

This note shall be modified as follows:

Note: The well pump that is existing is a Franklin Tri Seal 10GS30 based upon best records available. ~~This shall be verified on site during the construction process. The pump replacement shall be bid as an optional item and the contractor shall match the existing pump with the replacement.~~

Therefore the contractor is not responsible (1) for any pump verification and (2) there is no optional bid item for pump replacement.

END OF ADDENDUM NO. 1