



MONTANA FISH, WILDLIFE & PARKS

ADDENDUM NO. 1

TO: ALL BIDDERS OF RECORD

PROJECT: Whitefish Lake State Park Chip Seal

FWP PROJECT #: 7156421

DATE: February 28, 2022

FROM: Randi Rognlie, Project Manager

Acknowledge receipt of this addendum by inserting its number and date in the Proposal Form and on the Bid Envelope. Failure to do so may subject bidder to disqualification.

This Addendum forms a part of the Contract Documents. Clarification and/or modifications are as follows:

Section 02504 (and in reference to MPWSS 7th Edition, April 2021)

PART 2 PRODUCTS:

Section 2.2 AGGREGATE

Delete Referenced Table II in FWP specifications and *replace* with MPWSS Table 2 for 3/8" Seal Coat Aggregate – Table of Gradation, Section 2.2.G. MDT Type 1 Crushed Cover Aggregate-Cover Material specified in Section 701.02.8 and Table 701-12, also acceptable.

PART 3 EXECUTION:

Section 3.3 CONSTRUCTION METHODS:

D. APPLICATION OF ASPHALT MATERIAL

REMOVE:

- ~~1. Apply asphalt material at a rate of 0.35 gallons per square yard (1.6 L/m²) when using Emulsified Asphalt CRS 2 or CRS 2P, and at a rate of 0.50 gallons per square yard (2.3 L/m²) when using Liquid Asphalt MC 800 or MC 3000.~~

ADD:

1. Apply asphalt material at a minimum rate of .40 gallons per square yard when using Emulsified Asphalt CRS 2 or CRS 2P.