



MONTANA FISH, WILDLIFE & PARKS

ADDENDUM NO. 1

TO: ALL BIDDERS OF RECORD

PROJECT: Finley Point State Park Diversified Lodging

FWP PROJECT #: 7216609

DATE: March 1, 2022

FROM: Randi Rognlie, Project Manager

Acknowledge receipt of this addendum by inserting its number and date in the Proposal Form and on the Bid Envelope. Failure to do so may subject bidder to disqualification.

This Addendum forms a part of the Contract Documents. Clarification and/or modifications are as follows:

Section 133400

PART 2 PRODUCTS:

2.2 PREFABRICATED WOOD STRUCTURES

Add: A.1. Cabins shall be a 12'-0" X 12'-0" with a 6'-0" covered porch and may be a single room. Interior side walls shall be a minimum of 5'- 1/2" from floor decking to start of ceiling decking. Ceiling shall be a minimum 9'-2" from floor decking to ridge beam.

Add: to Paragraph B: Ceiling decking shall be 1X6 bevel-sided tongue and groove solid wood.