



MONTANA FISH, WILDLIFE & PARKS

ADDENDUM NO. 1

TO: ALL BIDDERS OF RECORD

PROJECT: Smith River State Park Human Waste Disposal System, Eden Bridge

FWP PROJECT #: 7216700

DATE: August 26, 2022

FROM: Randi Rognlie, Montana FWP Project Manager

Acknowledge receipt of this addendum by inserting its number and date in the Proposal Form and on the Bid Envelope. Failure to do so may subject bidder to disqualification.

This Addendum forms a part of the Contract Documents. Clarification and/or modifications area as follows:

1. Please see the revised plan set dated and stamped 8-15-2022 addressing #2 and #3 below:
2. The design has been modified to show the water tower being fed from downstream of the backflow prevention device in the SCAT building.
3. The holding tank HWA float has been adjusted to 75% of the tank capacity.
4. A substitution has been approved for the heater in the building. The product is a Raywall 5800 Series Garage/Workshop 240/208 V. Fan Forced Portable Heater.

END OF ADDENDUM NO. 1