ADDENDUM NO. 1

TO: ALL BIDDERS OF RECORD

PROJECT: REGION 7 HEADQUARTERS BOILER REPLACEMENT

FWP PROJECT #: 7219133

DATE: October 6, 2022

FROM: JEFFREY A. GRUIZENGA, PE

Acknowledge receipt of this addendum by inserting its number and date in the Proposal Form and on the Bid Envelope. Failure to do so may subject bidder to disqualification.

This Addendum forms a part of the Contract Documents. Clarification and/or modifications area as follows:

General:

- 1. All bids need to be received in Helena before the official time of bid.
- 2. FWP is recommending contractors do NOT send bids by USPS, but rather UPS or Fed Ex.
- Official award letter should be provided to successful contractor within 7 working days of bid opening.
- 4. No test and balance is required.
- 5. Balance valves on boiler in the detail is required but reuse of existing device is allowed.

Specification:

- 1. Section 15510 2.2.A Clarification: Performance listed in this section is incorrect for this project. The correct boiler performance is listed on the drawings in the equipment schedule. See Sheet ME3.1 for correct information.
- Section 15900 Energy Management and Control System Clarification: The current building temperature control contractor is not ATS as listed in the specification but Electro Controls, Billings 406.252.9975

Pre-Bid Walk Through Attendees

Jeff Gruizenga	Con'eer Engineering, Inc.	jeffg@coneer.com
Tom Mannatt	Montana Fish, Wildlife & Parks	tmannatt@mt.gov
Kirk Linebach	Allied Plumbing	alliedpb@gmail.com
Eddie Pulecio	MC Electric	Mcelectric59301@gmail.com

END OF ADDENDUM NO. 1